



C NO: 201/2019

Office of the Station Officer  
Fire and Rescue Station  
Nedumangad  
Dtd:13/06/2019

From,

Station Officer  
Fire and rescue Station  
Nedumangad

To,

Fr. Antony Raj  
Sarvodaya Central Vidyalaya  
Mar Ivanios Vidya Nagar  
Nalanchira, Thiruvananthapuram

Sub: Fire and Rescue Station Nedumangad:- Fire Approval  
certificate Issuing Reg,;


Ref: (1) Your Letter Dtd:11/06/2019

(2) Orde no F2-9400/16 Dtd:16/04/2019 Of Director General,  
Fire & Rescue Services, HQ TVPM

Vide reference cited (1) you have submitted the drawings Sarvodaya Central Vidyalaya, Mar Ivanios Vidya Nagar, Nalanchira, Thiruvananthapuram after installing Fire Fighting Installation for getting certificate of approval from Fire and Rescue Department. According to the drawing submitted Plinth area of the Education building is below 1000m<sup>2</sup> and Height is 15 mtr Vide ref. cited (2) Now no need to take Fire safety approval from the Fire and rescue Services department for this building.

Yours Faithfully



  
സ്റ്റേഷൻ ഓഫീസർ  
അഗ്നി രക്ഷാ നിലയം  
നെടുമങ്ങാട്  
പിൻ-69 5561